


- GENERAL NOTES:**
- ALL DIMENSIONS ARE IN MM UNLESS UNTIL IT IS SPECIFIED.
 - THIS DRAWING IS PREPARED IN CONJUNCTION WITH THE LATEST ARCHITECTURAL, STRUCTURAL & MEP DRAWING RECEIVED AS MENTIONED IN THE DRAWING REFERENCES GIVEN BELOW.
 - ARCHITECT TO CONFIRM THE HEIGHT.
 - WE HAVE ASSUMED THE DISTANCE BETWEEN CEILING & FALSE CEILING IS MORE THAN 800mm, HENCE DETECTORS ABOVE FALSE CEILING ARE PROVIDED.
 - FM-FAULT ISOLATOR MODULE WILL BE PLACED AFTER EVERY 20 DEVICES & 20 DETECTORS.
 - CRM-CONTROL RELAY MODULE WILL CONTROL ALL FIRE DAMPERS, OUT DOORS UNITS, ACCESS CONTROL & ALL PRESS. FANS (EMERGENCY) & MOTORIZED DAMPERS FOR ALL PRESSURIZATION FANS.

LEGEND:-

SYMBOL	DESCRIPTION	MOUNTING HEIGHT FROM F.F.L IN MM
●	SPEAKER FOR VOICE EVACUATION SYSTEMS	ON F.CEILING
⊙	SMOKE DETECTOR (ABOVE FALSE CEILING)	ON CEILING
⊙	SMOKE DETECTOR (BELOW FALSE CEILING)	ON F.CEILING
⊙	LASER DETECTOR (ABOVE FALSE CEILING)	ON CEILING
⊙	MANUAL CALL POINT (MCP)	1400
⊙	FIRE ALARM HOOTER	2400
⊙	FIRE INTERCOM SYSTEM	ON WALL
⊙	CONTROL MODULE	
⊙	RESPONSE INDICATOR (RI)	
⊙	CARBON MONOXIDE SENSOR (CO)	
⊙	FIXED DOME VARI-FOCAL CAMERA (IP BASED CCTV)	ON CEILING
⊙	PTZ CAMERA (IP BASED CCTV)	ON CEILING
—	25mm DIA CONDUIT FOR DETECTOR	
—	25mm DIA CONDUIT FOR SPEAKER	
—	25mm DIA CONDUIT FOR HOOTER	
—	25mm DIA CONDUIT FOR CCTV	
—	25mm DIA CONDUIT FOR BMS	

ALL MS CONDUITS ARE 25MM DIA

DEVELOPMENT
CAMELLIAS
DLF Phase V Gurgaon



CLIENT
DLF

DLF LIMITED.
DLF Gateway tower, R Block, DLF City, Phase III, Gurgaon-122002, Haryana(India)
Tel: 91 124 4769000, Fax: 91 124 4769250.

PROJECT MANAGEMENT CONSULTANTS
Hill International
Hill International Project Management (India) Pvt. Ltd.
Unit 1-2-3, 1st Floor, Augusta Point, Sector 53, Golf Course Road, Gurgaon, India.
Tel: +91 124 4076314

ARCHITECTS
Architect Hafeez Contractor
29 Bank Street, Mumbai 400023, Tel 22 22661920, Fax 22 22664737

STRUCTURAL ENGINEERS
CBM Engineers India
101, Sai Avenue, Amritsar Road, Vija Road, Haryana, India. Phone: 296078
Ph: +0091 2481835
Email: cbm@cbmengineers.com
Website: www.cbmengineers.com

MEP Consultants
Meinhardt India Pvt Ltd
A-8 Sector 16, Noida 201-301 LIP India Tel: 91 120 2516165, Fax: 91 120 2515745

FIRE FIGHTING CONSULTANTS
Tenable - Fire Engineering Consultancy
Middleview, Faringdon Road, Southmoor, Oxfordshire OX12 5BG, T 44 186 5621482, F 44 777 853 3965

COSTING CONSULTANTS
KPK - Cost Consultants
865 Mountbatten Road #07-01, Kallong Shopping Centre, Singapore 437944, Tel 65 9633030 Fax 65 9626533

QUANTITY SURVEYORS
KPK Quantity Surveyors India Pvt Ltd,
816 Viasa Deep Towers, District Centre Janak Puri, New Delhi, 110058

LANDSCAPE CONSULTANTS
MFPF / M.PAUL FRIDBERG & PARTNERS
41, East 11th street, New York, NY 10003

MAIN CONTRACTOR
Leighton India Contractors Pvt Ltd
3/F, Tower-A, Ocus Technopolis, Golf Course Road, Sector 54, 122002 Haryana, India

Rev no	Description	Drawn	Checked	Date
R0	FOR INFORMATION	BALAJI	TARUN	16.05.14
Issue :	FOR INFORMATION			
SCALE:	1:100			
DATE:	16/05/14			
Drawn By	BALAJI	Checked By	TARUN	

DRAWING TITLE :
BASEMENT-3
BLOCK-A1
ELV CONDUIT LAYOUT

SHEET NUMBER:
D01-DWG-BS3-ELV-01-001
SHEET 1-12

Rev: R0

BASE DRAWING REFERENCE			
Architecture	Drawing No.	Rev. No.	Date
1	GFC-AR-AHC-DWG-BS-B1-19	R2	02.06.14
Structural	Drawing No.	Rev. No.	Date
1	D01-DWG-BS-CS-02-001A	R1	03.06.14
Electrical	Drawing No.	Rev. No.	Date
1	D01-DWG-BS3-EL-22-002	R1	22.05.14